



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
**TÜRK STANDARDLARINA UYGUNLUK BELGESİ**  
**TURKISH STANDARDS INSTITUTION**  
**CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS**

Markanın Tanımı Description of the Mark  
TSE veya/or  veya/or T S E

<b>BELGE NUMARASI</b> REFERENCE NUMBER OF LICENCE	021481-TSE-01/02
<b>BELGENİN İLK VERİLİŞ TARİHİ</b> DATE OF FIRST ISSUE OF LICENCE	31.12.2013
<b>BELGENİN SON GEÇERLİLİK TARİHİ</b> LICENCE VALID UNTIL	24.08.2024
<b>BELGE SAHİBİ KURULUŞUN ADI</b> NAME OF THE LICENCE HOLDER	KALTES ELEKTRİK SANAYİ VE TİCARET LİMİTED ŞİRKETİ
<b>BELGE SAHİBİ KURULUŞUN ADRESİ</b> ADDRESS OF THE LICENCE HOLDER	İKİTELLİ OSB MAH. ATATÜRK BLV. NO:58 /2 BAŞAKŞEHİR İSTANBUL/TÜRKİYE
<b>ÜRETİM YERİ ADI</b> NAME OF THE MANUFACTURING PLACE	İkitelli OSB Ziya Gökalp Mah. Atatürk Bulv. No58/1-2 İkitelli İstanbul
<b>ÜRETİM YERİ ADRESİ</b> ADDRESS OF THE MANUFACTURING PLACE	İKİTELLİ OSB ZİYA GÖKALP MAH. ATATÜRK BULV. NO58/1-2 İKİTELLİ İSTANBUL İSTANBUL / TÜRKİYE
<b>İPTAL EDİLEN BELGE NUMARASI (Varsa)</b> INDICATION OF SUPERSEDED LICENCE (if any)	021481-TSE-01/01
<b>TESCİLLİ TİCARİ MARKASI</b> REGISTERED TRADE MARK	ŞEKİL+SETLAK
<b>İLGİLİ TÜRK STANDARDI</b> RELATED TURKISH STANDARD	TS EN 62208 / 16.04.2014
<b>BELGE KAPSAMI</b> SCOPE OF LICENCE	

-EMPTY ENCLOSURES (Metal)

-SET-T-WI In door, IP 54, IK 10, Wall mounting, from 300x400x175 mm to 1000x1200x350 mm  
-SET-T-WH Out door, IP 55, IK 10, Wall mounting, from 300x400x175 mm to 1000x1200x350 mm  
-SET-T-WHP Out door, IP 66, IK 10, Wall mounting, from 300x400x175 mm to 1000x1200x350 mm  
(S.C 04.08.2020)  
-SET-D-FIP In door, IP 54, IK 10, Ground mounting from 400x1100x400 mm to 1200x2100x2100 mm  
-SET-D-FI In door, IP 41, IK 10, Ground mounting, from 400x1100x400 mm to 1200x2100x2100 mm  
-SET-D-FH Out door, IP 55, IK 10, Ground mounting, from 400x1100x400 mm to 1200x2100x2100 mm  
-SET-R-W In door, IP 20, IK 10, Wall mounting from 500x335x450 mm to 550x795x600 mm  
-SET-R-F In door, IP 20, IK 10, Ground mounting, from 600x900x600 mm to 800x2200x1000 mm  
-SET-T-WS In door, IP 54, IK 10, Wall mounting, from 250x300x150 mm to 1880x1035x150 mm

*e-imzalı/e-signed*

13.12.2023

On Behalf Of The Head Of Certification Center  
AKDOĞAN BULUT

MANAGER OF THE TSE ISTANBUL CERTIFICATION  
DEPT.P

\*This certificate also shows that the production place of the certified product meets the requirements of Institute.

\*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

\*TSE \* Address: Çayırova Tren İstasyonu Yanı ÇAYIROVA/GEBZE \* Telephone: 2627231273\* Fax: 2627231606

\*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail

:bmb@tse.org.tr , web : www.tse.org.tr

